

City of Meridian Public Works

Hot Tap Requirements and Approved Hot Tapper List

(hot taps of 4 inch or greater diameter)

Hot Tap Requirements

1. Hot taps will be performed only by people on the approved hot tappers list attached to this document.
2. Hot taps will be performed according to the Transmate TapMate Pipe Drilling Machine manual. The manual will be on-site during hot taps.
3. The contractor shall furnish all needed tools for all testing of the saddle as well as performing the tap.
4. The tapping saddle shall be air tested to 100 psi in the presence of the inspector.

Requirements to be added to list of approved hot tappers:

1. The trainee shall do ten successful taps with an approved hot tapper in the presence of an inspector from the City of Meridian.
2. After a successful hot tap, the inspector will give the hot tap trainee a signed business card. The trainee is responsible to retain the card as proof of the successful hot tap. When a trainee presents ten cards to the Public Works department, they will be added to the list of approved hot tappers.
3. An experienced hot tapper may be added to the list of approved hot tappers through a written endorsement from a reference currently on the approved list. The written endorsement can be submitted to the project inspector shall be approved by the project manager.

Name	Company
Jon Bell	HD Water Works
Sean Davis	HD Water Works
Rick Bress	HD Water Works
Todd McClintick	United Pipe & Supply
Scott Kuhn	United Pipe & Supply
Frank McClintick	United Pipe & Supply
Ansel Irminger	Star Construction
Butch	Star Construction
Brad Everhart	Owyhee Construction
Don Lobie	Owyhee Construction
Ted Hyslop	Knife River